


APPENDIX B

ELECTRICITY GENERATION

The Corporation continued to cater for the electricity needs in the Maltese islands, through its two power stations, the one at Marsa and the other at Delimara with an installed capacity of 267MW and 304MW respectively.

In 2009 there had been a drop of 6.2% in the amount of units generated. This was also reflected in the maximum peak demands, where in certain months it was lower by up to 10%. The reason for this drop was mainly attributed to the rise in electricity tariffs. This rise in tariffs reduced a large amount of wastage that the Maltese families were accustomed to. The weather conditions though, still played a dominant factor in the use of electricity, and the demand for electricity fluctuated irregularly during the past months. The peak demand registered in August 2009, was 403MW as compared with the 424MW maximum demand in the previous year.

All efforts were made to keep the plant at Marsa in optimum operating condition, by means of regular inspections, overhauls and maintenance. The statutory inspections of pressure vessels, boilers and safety equipment were carried out as in previous years. Similar procedures were adopted to the turbines and auxiliaries to prevent forced shut downs particularly during the peak summer months.



Other major works carried out at the Marsa Power Station included:

- **turbine No. 4 trust bearing inspections and repair;**
- **turbine No. 4 replacement of most sea-water pipe work;**
- **change-over of Turbine No.6 to new Siemens switchgear;**
- **fuel Tank No. 2 inspection was completed;**
- **re-circulation lines on feed-pumps Nos. 5 to 7 were completed;**
- **turbine No. 8 inspection: replacement of H2 seal, HPH tube leak; rehabilitated seawater discharge line 'B' and repaired throttle valve.**

The long-serving plant at the Marsa Power Station, continues to prove a great burden to the maintenance section, since the number of faults and breakdowns being registered are on the increase. The replacement of seawater lines, boiler tube leaks, feed pump failures, damaged bellows and burnt motors all reflect this situation.

A new automatic emission monitoring system was commissioned and the QAL 2 were conducted. The system was thus calibrated in July and with the new system now in service, emissions from the station are being adequately monitored online and all readings duly recorded.

| SYSTEM GENERATION FIGURES | | |
|---|------------------|------------------|
| | Actual | Actual |
| | 2008 | 2009 |
| TOTAL GENERATING CAPACITY | | |
| MWh Generated Marsa B Stn (Steam) | 1,058,949 | 966,151 |
| MWh Generated Marsa B Stn (Gas) | 5,739 | 5,900 |
| MWh Generated Delimara Stn (Steam) | 859,904 | 836,970 |
| MWh Generated Delimara Stn (Gas) | 4,975 | 15,756 |
| MWh Generated Delimara Stn (CCGT) | 382,504 | 342,863 |
| Total MWh Generated | 2,312,071 | 2,167,400 |
| Units consumed in Stations (MWh) | 127,142 | 121,705 |
| Units sent out from Station busbars (MWh) | 2,184,929 | 2,045,935 |
| System maximum demand (MW) | 424 | 403 |
| System maximum demand (MVar) | 210 | 165 |
| FUEL CONSUMPTION (MTONS) | | |
| Heavy Fuel Oil (Marsa) | 329,102 | 303,029 |
| Gas Oil (Marsa) | 2,339 | 2,338 |
| Heavy Fuel Oil (Delimara) | 228,169 | 220,457 |
| Gas Oil (Delimara) | 2,020 | 5,541 |
| Gas Oil (Delimara CCGT) | 77,803 | 69,609 |
| FUEL RATES (KG/KWH) | | |
| Steam Units Marsa | 0.311 | 0.314 |
| Steam Units Delimara | 0.265 | 0.263 |
| Gas Turbine Unit Marsa | 0.408 | 0.396 |
| Gas Turbine Unit Delimara | 0.406 | 0.352 |
| CCGT | 0.203 | 0.203 |
| PLANT CAPACITY FACTOR % | | |
| Steam Units Marsa | 82.23 | 78.49 |
| Steam Units Delimara | 95.10 | 92.40 |
| Gas Turbine Unit Marsa | 38.76 | 39.65 |
| Gas Turbine Units Delimara | 42.10 | 46.90 |
| CCGT | 70.40 | 70.00 |
| STATION THERMAL EFFICIENCY % | | |
| Steam Units Marsa* | 26.67 | 26.27 |
| Steam Units Delimara* | 31.78 | 31.86 |
| Gas Turbine Unit Marsa | 20.43 | 21.09 |
| Gas Turbine Units Delimara | 22.09 | 23.77 |
| CCGT | 39.48 | 39.28 |


*Efficiency calculated on Net CV



Wärtsilä oil-fired engines

In the diesel process, liquid fuel is injected into the cylinder at high pressure by camshaft-operated pumps. The fuel is ignited instantly due to the high temperature resulting from the compression.

Combustion takes place under constant pressure with fuel injected into the cylinder during combustion. After the working phase, the exhaust gas valves open and the cylinder is emptied of exhaust gases. With the piston in its upper position, the inlet valves open just before the exhaust gas valves close, and the cylinder is filled with air. In Wärtsilä engines the inlet valves close just before the piston reaches the bottom dead centre. This method, called "Miller timing", reduces the work of compression and the combustion temperature, which results in higher engine efficiency and lower emissions.



Wärtsilä 20 main technical data

Wärtsilä 32 main technical data

Wärtsilä 46 main technical data

The Wärtsilä 46 is a medium-speed engine for which reliability and total economy have been the guiding principles. Extensive testing in our modern diesel laboratory backed up by several thousand running hours have made the Wärtsilä 46 a really reliable diesel engine. Laboratory testing is full-scale engine testing: it covers various types of endurance testing, and also combustion measurements and system optimizations. All these confirm theoretical calculations,

simulations as well as performance mapping of such factors as heat balance, fuel and lube oil consumption, exhaust emission, noise and vibration level.

Wärtsilä engine designs are based on generations of know-how combined with innovations in response to customer needs. The Wärtsilä 46 engine offers customers the following **benefits**:

- Real reliability
- Low operating costs
- Low exhaust gas emissions
- Easy and cost-effective installation
- Proven flexible mounting technology
- Easy maintenance



Technical data 50 Hz/500 rpm

| | | 12V46* | 18V46* |
|-----------------------|--------|--------|-------------|
| Power, electrical | kW | 11384 | 17076 |
| Heat rate | kJ/kWh | 7732 | <u>7732</u> |
| Electrical efficiency | % | 46,6 | 46,6 |

Technical data 60 Hz/514 rpm

| | | | |
|-----------------------|--------|-------|-------|
| Power, electrical | kW | 11384 | 17076 |
| Heat rate | kJ/kWh | 7732 | 7732 |
| Electrical efficiency | % | 46,6 | 46,6 |

Dimensions and dry weight of generating sets

| | | | |
|--------|-------|-------|-------|
| Length | mm | 15400 | 18780 |
| Width | mm | 5090 | 5320 |
| Height | mm | 5700 | 6020 |
| Weight | tonne | 265 | 358 |

Heat rate and electrical efficiency at generator terminals, including engine-driven pumps. ISO 3046 conditions and LHV. Tolerance 5%. Power factor 0.8.

* Gas-diesel version available.

Read more from our Wärtsilä 46 technology review brochure.

Wärtsilä 46F main technical data

Contact us >



© 2011 Wärtsilä